

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES**

Memo No : IND/WB/FES/20192020/51342

DATE: 12/04/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**DELHI PUBLIC SCHOOL ASANSOL
G+3 STORIED EDUCATIONAL BUILDING NAME AND STYLE AS DELHI PUBLIC
SCHOOL ASANSOL, AT R.S.PLOT
NO.241(P),361,230,233,234,231,KH.NO.652,653,14994,176,203,356,117,J.L.NO.75,MOUZ
A-TALBERIA ASANSOL
Asansol F.S., Salanpur PS,
Paschim Bardhaman - 713359 .**

**Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction
of G + 3 storied building under group Educational at the premises no.- G+3 STORIED
EDUCATIONAL BUILDING NAME AND STYLE AS DELHI PUBLIC SCHOOL
ASANSOL, AT R.S.PLOT
NO.241(P),361,230,233,234,231,KH.NO.652,653,14994,176,203,356,117,J.L.NO.75,MOUZ
A-TALBERIA ASANSOL, PS.Salanpur, DIST.Paschim Bardhaman PIN- 713359**

This is in reference to your Application No. IND/WB/FES/20192020/51342, dated 12/04/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 3 storied building under group Educational at the premises no.- G+3 STORIED EDUCATIONAL BUILDING NAME AND STYLE AS DELHI PUBLIC SCHOOL ASANSOL, AT R.S.PLOT NO.241(P),361,230,233,234,231,KH.NO.652,653,14994,176,203,356,117,J.L.NO.75,MOUZ A-TALBERIA ASANSOL, PS.Salanpur, DIST.Paschim Bardhaman PIN- 713359.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. 1. Minimum 3nos ABC (6kgs) and 3 Carbondioxide (4.5kgs) , 3no Water type(9lts.) Fire extinguisher shall be kept at each floor as well as Manual Call point & Public address system shall be arranged within three months.
 2. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
 3. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.
 4. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
 5. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
 6. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
 7. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.
 8. Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.
 9. Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
 10. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
 11. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
 12. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
 13. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
 14. Floor numbers and directional sign of escape route shall be displayed prominently.
 15. This Fire Safety certificate is valid for three years and has to be renewed every three year from the date of issue of this letter.
- Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the FSC shall be treated cancelled.

**Divisional Fire Officer
West Bengal Fire & Emergency Services**

Signature Not Verified
Digitally signed by NITAI
CHATTOPADHYAY
Date: 2019.04.12 02:40:45 PDT